

**SUBDIVISION REVIEW FORM
FIRE DEPARTMENT**

TO: ROCKPORT FIRE CHIEF

FROM: ROCKPORT PLANNING OFFICE/PLANNING BOARD

The Planning Board is currently reviewing a SUBDIVISION application and would appreciate your comments regarding the proposed SUBDIVISION and your Department's capacity to safeguard life and property.

SUBDIVISION NAME: M. RICHARDSON FINAL SUBDIVISION PLAN

LOCATION: OFF OF TERRIER CIRCLE, ROCKPORT ME

PROJECT DESCRIPTION: PROPOSED 3 LOT SUBDIVISION ON 13 ACRES

Please check the appropriate response and offer any relevant comments.

I anticipate no significant problem with the proposal.

I would like to discuss the proposed Subdivision with the Board.

Comments of Recommendations:

The entire subdivision off from Old Country has no water sources for the Fire Department. Any incident would require shuttling water from either the Rockland End of Old County or Commercial St Rockport. The distance to either fire hydrant is roughly 8/10 of a mile. Rockport Fire currently has mutual aid agreements with 6 additional Towns to assist with water supply if needed.

Planning Board meeting date: 24 June 2021 at 5:30pm

Chief Peasley
FIRE CHIEF

6/16/2021
DATE

